

102 年度放流水水質監測結果分析表

項目 時間	pH 值	水溫 (°C)	DO (mg/L)	BOD (mg/L)	COD (mg/L)	油脂 (mg/L)	SS (mg/L)	真色 色度
102.01.14	7.4	21.3	4.9	ND	ND	ND	ND	ND
102.02.21	7.6	24.1	6.1	ND	ND	ND	ND	ND
102.03.18	8.2	23.9	6.7	ND	ND	ND	ND	<50
102.04.09	8.1	24.5	6.1	ND	ND	ND	ND	ND
102.05.15	8.1	29.6	6.8	ND	34.4	ND	ND	ND
102.06.05	7.9	30	5.9	ND	ND	ND	ND	<50
102.07.22	8.2	32.9	4.3	ND	ND	ND	ND	ND
102.08.15	--	--	--	--	--	--	--	--
102.09.09	8.2	31.6	4.3	ND	43.9	ND	ND	ND
102.10.21	8.1	29	7.4	ND	ND	ND	ND	ND
102.11.25	8.2	27.7	5.2	ND	ND	ND	ND	<50
102.12.23	7.4	24.2	5.2	ND	21	ND	ND	ND
營建工地放 流水標準	6.0~9.0	5~9 月<38 °C， 10~翌年 4 月 <35°C	-	30	100	-	30	550

註：“<Z”表示檢驗值低於檢量線最低點濃度(Z)而高於方法偵測極限(MDL)濃度；”ND”表示檢驗值低 MDL