

108 年度工區放流水水質監測結果彙整表

時間	項目	pH 值	水溫 (°C)	DO (mg/L)	BOD (mg/L)	COD (mg/L)	油脂 (mg/L)	SS (mg/L)	真色色度
108.01.21 (擴充園區-土建二標)		7.8	20.5	8.9	ND	5.4	2.8	6.4	<50
108.02.18 (擴充園區-土建一標)		7.8	24.3	8.3	ND	16.9	4.2	10.6	<50
108.03.14 (擴充園區-土建三標)		8.4	24.2	8.3	ND	9	ND	7	<50
108.04.17(光晟生技)		7.6	28.5	6.1	ND	ND	ND	ND	ND
108.05.09(翰德工業)		7.8	28.2	4.8	2.1	17.7	ND	27.8	<50
108.06.04 (水資源處理場擴建工程)		7.4	27.9	6.1	ND	6.4	ND	13.6	<50
108.07.07 (擴充園區-土建三標)		8.0	30.5	7.3	ND	8.1	ND	25.8	<50
108.08.26 (擴充園區-土建二標)		8.2	29.4	6.4	ND	5.7	ND	11.9	<50
108.09.02(光晟生技)		8.8	30.6	7.8	3.4	6.6	ND	4.6	<50
108.10.03 (擴充園區-土建一標)		7.6	29.7	5.6	ND	13.7	ND	13.2	<50
108.11.11 (擴充園區-土建二標)		7.8	23	7.8	ND	8.6	ND	27.3	<50
108.12.10(翰德工業)		7.5	29.5	7.4	ND	1.3	ND	23.8	ND
	MDL	--	--	--	2.0	1.2	2.0	2.5	1.4
	營建工地放流水標準	6.0~9.0	5~9 月 <38°C , 10~翌 年 4 月 <35°C	-	30	100	-	30	550

註：“<Z”表示檢驗值低於檢量線最低點濃度(Z)而高於方法偵測極限(MDL)濃度；”ND”表示檢驗值低 MDL