

歷次營建噪音監測結果比較表

單位：dB(A)

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>	
	75		100		75		100		75		100	
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
93.10.25	45.1	47.3	70.1	72.0	44.3	46.8	55.8	62.1	65.4	48.3	65.4	70.9
93.11.22	47.9	60.4	59.5	72.0	46.5	56.7	60.2	76.7	47.2	62.6	64.4	79.4
93.12.06	46.0	56.5	53.6	68.1	46.8	58.6	59.7	66.3	46.3	55.7	59.6	73.5
94.01.04	47.3	49.6	51.4	59.3	46.1	46.8	63.2	66.8	45.2	46.8	63.8	66.8
94.01.11	51.4	52.0	60.1	60.8	56.4	57.8	71.6	75.0	48.6	49.9	64.8	66.1
94.02.14	49.8	51.9	60.3	64.3	46.3	48.9	68.4	70.3	47.8	50.4	63.5	66.3
94.03.08	52.7	53.4	65.8	67.2	51.1	53.3	59.4	67.2	43.8	55.1	68.4	71.5
94.04.14	56.3	62.2	62.4	75.4	59.1	61.6	63.4	78.7	58.6	60.8	69.4	77.8
94.04.26	59.7	61.2	71.6	78.5	58.8	61.6	71.4	79.3	54.2	56.5	66.3	70.1
94.05.09	-	-	-	-	55.7	56.8	68.3	72.4	54.2	56.3	64.3	70.2
94.05.23	-	-	-	-	53.4	61.5	59.2	69.0	44.5	58.1	59.7	75.8
94.06.01	40.3	55.4	51.7	65.1	47.8	64.1	51.2	78.5	46.7	52.8	50.8	73.2
94.06.17	51.5	66.6	61.1	78.3	51.1	53.2	62.4	70.9	50.3	56.3	63.7	72.1
94.07.05	48.5	63.9	55.9	75.6	60.1	70.2	73.4	78.2	43.1	43.5	49.8	60.6
94.07.22	46.7	49.9	54.2	58.3	53.0	62.6	62.3	69.5	46.7	46.9	54.7	57.3
94.08.01	56.4	57.7	72.4	75.1	50.8	54.0	62.9	64.5	43.1	56.5	55.9	70.8
94.08.11	46.4	57.3	55.1	69.5	48.7	49.1	60.1	65.2	40.5	40.3	45.8	57.3
94.09.05	38.5	58.8	45.4	65.7	33.1	53.5	40.9	68.1	33.4	54.9	41.5	66.5
94.09.13	45.3	62.5	50.1	75.2	45.5	62.1	61.7	70.3	38.9	56.7	44.3	72.4
94.10.03	41.4	60.0	51.4	74.6	52.2	59.6	56.6	75.8	46.1	51.1	55.0	72.9
94.10.18	40.1	55.9	46.4	67.8	47.5	49.5	53.8	65.7	43.1	53.6	49.0	69.5
94.11.01	40.9	56.5	52.9	70.4	38.3	51.3	47.1	64.1	37.7	47.6	45.1	62.2
94.11.17	39.9	42.4	49.6	53.8	36.9	39.9	43.1	56.5	35.7	45.9	41.5	51.4
94.12.01	30.1	50.8	49.8	69.5	37.4	43.6	50.6	61.1	36.8	43.8	43.5	54.9
94.12.15	37.8	47.5	44.9	56.8	36.7	60.0	46.4	72.9	33.2	40.5	41.4	54.2
95.01.20	64.5	67.9	74.9	78.3	60.3	63.8	74.2	75.0	61.5	64.8	75.5	76.1
95.02.22	56.6	62.4	65.6	78.1	49.0	61.2	58.5	73.8	50.7	61.7	60.3	73.9
95.03.23	60.1	61.5	72.1	75.3	62.4	64.0	77.9	78.9	63.1	64.3	77.2	79.3
95.04.19	57.5	60.1	69.2	71.5	60.5	62.4	69.9	71.1	61.0	70.3	66.8	77.5
95.05.26	59.6	61.1	67.7	69.6	58.8	61.6	68.8	72.2	57.1	61.4	63.1	65.2
95.06.22	60.8	63.3	73.3	76.4	58.2	61.9	66.0	68.6	55.5	66.5	58.4	71.5
95.07.20	65.1	69.2	75.9	77.3	64.5	68.4	74.2	76.9	59.0	69.5	68.4	78.6
95.08.18	65.4	65.9	78.2	79.5	64.7	65.4	73.9	78.5	63.4	65.2	75.4	79.4

註：採用行政院環保署 102 年 8 月 5 日公告修正：「噪音管制標準」之第六條「營建工程噪音管制標準」。

歷次營建噪音監測結果比較表(續 1)

單位：dB(A)

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>	
	75		100		75		100		75		100	
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
95.09.20	62.8	68.0	76.6	77.6	59.4	67.2	71.6	75.7	58.4	60.0	68.0	68.0
95.10.26	64.3	65.3	76.3	78.2	61.5	65.4	74.9	77.6	58.3	67.2	70.3	78.8
95.11.24	62.3	67.3	73.8	78.2	63.4	66.8	73.4	78.1	62.0	65.3	68.4	75.9
95.12.18	56.9	67.5	63.5	74.2	59.0	67.1	67.5	75.0	56.5	68.8	66.3	77.6
96.01.22	62.2	62.4	71.7	79.4	62.3	68.2	76.7	81.9	64.1	67.4	78.9	80.7
96.02.01	60.6	68.2	76.7	81.5	70.5	71.2	86.1	86.3	65.3	68.5	71.8	80.3
96.03.01	58.6	65.5	68.3	80.2	67.4	67.5	76.6	79.3	55.8	61.7	66.5	74.5
96.04.16	62.2	62.4	71.7	79.4	62.3	68.2	76.7	81.9	64.1	67.4	78.9	80.7
96.05.08	60.6	68.2	76.7	81.5	70.5	71.2	86.1	86.3	65.3	68.5	71.8	80.3
96.06.06	58.6	65.5	68.3	80.2	67.4	67.5	76.6	79.3	55.8	61.7	66.5	74.5
96.07.16	63.6	66.1	77.7	78.7	66.3	66.5	80.3	82.8	64.0	64.4	77.9	80.1
96.08.01	52.8	55.5	62.0	70.4	53.5	55.7	64.9	69.9	53.4	56.4	70.9	74.0
96.09.21	57.0	59.7	71.8	77.5	55.0	60.2	68.5	76.0	52.6	60.9	61.1	75.6
96.10.22	60.3	62.5	72.4	76.0	58.0	60.9	72.9	75.3	62.0	62.5	75.0	77.9
96.11.06	54.5	54.8	67.9	73.8	52.6	55.8	69.1	74.5	46.0	48.3	55.5	65.7
96.12.10	56.6	62.0	68.3	79.5	54.9	58.1	72.2	76.7	56.1	60.6	72.2	75.4
97.01.29	56.9	58.9	72.3	75.3	51.4	56.9	64.5	68.0	53.8	53.9	63.0	69.2
97.02.15	55.1	57.6	64.0	70.9	55.8	59.2	67.8	74.6	54.9	57.2	67.4	72.8
97.03.11	48.8	58.8	67.5	81.2	54.7	71.7	64.3	86.4	59.2	61.4	75.6	87.2
97.04.08	55.3	69.7	63.4	82.6	55.1	67.7	67.1	77.2	54.5	67.8	66.6	77.8
97.05.05	46.5	55.5	61.1	68.5	41.4	65.8	44.3	78.6	40.5	59.9	44.1	66.7
97.06.10	68.4	66.3	78.8	80.2	60.3	65.7	75.6	79.0	58.6	67.0	72.8	78.5
97.07.15	58.6	60.2	72.4	76.5	57.3	61.9	71.1	74.4	59.9	61.9	71.6	73.9
97.08.05	50.6	61.3	59.4	74.9	57.8	61.1	68.2	71.0	55.0	60.3	59.0	67.2
97.09.01	58.1	66.9	63.2	81.8	56.0	71.2	69.6	78.6	56.1	65.0	68.8	73.7
97.10.09	68.6	70.8	79.4	84.5	67.5	69.1	77.0	86.3	68.1	71.4	76.3	83.0
97.11.04	63.8	64.2	72.2	73.6	62.8	63.5	69.7	72.9	58.7	64.4	67.9	72.4
97.12.02	62.5	64.9	74.8	77.2	63.7	63.8	69.5	74.5	59.4	63.2	68.3	73.2
98.01.08	64.7	71.0	75.4	81.8	64.7	73.2	73.7	84.0	65.5	72.2	72.4	85.2
98.03.03	63.8	69.2	74.1	76.4	66.4	68.8	74.4	76.4	67.3	71.4	75.6	78.0
98.04.07	60.1	65.3	75.2	80.0	59.8	62.7	69.9	73.1	59.2	61.8	68.2	70.5
98.05.14	68.1	73.8	76.3	76.4	66.3	67.4	73.0	75.4	68.4	70.5	72.4	75.9
98.06.11	51.3	60.0	52.3	68.0	49.9	63.7	51.4	69.7	49.4	65.8	62.8	71.0

註：採用行政院環保署 102 年 8 月 5 日公告修正：「噪音管制標準」之第六條「營建工程噪音管制標準」。

歷次營建噪音監測結果比較表(續 2)

單位：dB(A)

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>	
	75		100		75		100		75		100	
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
98.07.02	57.1	73.3	67.0	78.6	56.7	73.4	65.2	77.7	46.5	73.0	58.5	76.4
98.08.06	63.0	63.0	66.7	69.4	62.9	65.3	67.2	72.0	62.6	68.0	63.8	73.4
98.09.04	65.4	72.2	69.5	79.3	67.5	74.8	73.2	82.0	66.6	74.5	70.2	81.1
98.10.13	66.3	73.2	71.2	80.8	65.7	67.9	69.7	75.2	67.6	73.4	77.8	82.0
98.11.10	46.7	60.3	51.4	62.8	42.0	58.9	49.7	65.0	41.9	58.8	48.9	63.3
98.12.10	60.1	66.3	64.0	72.9	62.8	68.7	68.1	75.4	61.9	71.7	65.3	77.1
99.01.04	61.3	64.6	65.3	70.0	65.9	69.6	71.5	75.3	61.3	68.8	64.7	74.0
99.02.09	64.0	67.4	68.9	73.0	64.6	70.3	70.1	76.1	63.8	71.0	67.3	76.4
99.03.08	51.0	56.3	54.3	65.4	51.0	60.9	56.0	70.2	51.4	59.4	55.4	68.8
99.04.07	57.1	60.0	68.9	73.6	58.1	59.9	69.0	72.4	56.6	59.6	66.2	72.3
99.05.11	58.4	63.5	70.7	78.8	54.1	59.6	64.1	71.5	57.7	61.9	68.1	76.2
99.06.07	51.2	57.0	54.4	66.0	50.7	60.0	55.0	71.1	51.3	57.6	56.2	69.5
99.07.12	64.1	68.3	69.5	74.5	60.3	65.9	65.4	72.6	66.4	69.5	70.4	74.3
99.08.19	62.8	69.0	68.1	75.3	60.9	68.6	65.9	75.5	66.7	69.2	71.8	75.0
99.09.03	62.6	68.3	67.9	74.5	61.0	68.5	66.0	75.3	67.1	69.7	72.2	75.5
99.10.05	54.2	62.3	65.5	81.5	52.4	54.5	64.8	69.3	54.2	56.7	65.5	69.3
99.11.03	59.0	60.9	76.0	79.8	58.4	61.0	75.3	80.8	57.7	62.3	74.4	81.0
99.12.09	50.8	55.5	60.4	66.9	53.9	57.1	64.1	70.2	53.2	55.9	64.4	69.9
100.01.06	54.4	56.5	67.8	71.5	54.7	56.6	66.1	73.7	56.2	57.6	66.2	73.6
100.02.24	52.3	58.7	60.9	73.2	48.7	49.8	53.2	62.9	49.7	60.1	56.0	70.9
100.03.15	65.0	64.7	69.9	73.3	66.8	71.8	72.5	78.8	65.0	72.3	68.5	78.8
100.04.14	54.0	60.6	64.8	71.0	47.7	63.8	58.0	73.9	46.2	49.1	55.0	63.3
100.05.09	58.4	65.0	74.8	69.6	56.1	60.4	74.3	77.8	67.6	73.4	80.6	83.1
100.06.09	56.9	66.1	69.0	84.1	49.2	59.2	63.0	71.8	42.7	58.0	53.7	72.2
100.07.27	52.1	56.2	61.9	67.7	53.9	56.7	64.1	69.6	53.2	58.0	64.4	71.1
100.08.19	59.5	60.8	74.4	74.5	52.5	63.1	66.3	74.2	45.5	56.0	54.8	67.0
100.09.02	51.4	53.9	56.5	64.6	50.8	58.4	56.0	67.9	52.9	62.1	65.9	66.8
100.10.06	48.8	58.1	60.4	65.8	55.2	58.5	60.9	65.9	57.1	58.5	65.1	66.5
100.11.17	53.9	59.3	62.1	70.6	52.3	55.1	59.7	65.6	55.3	57.3	65.9	70.5
100.12.12	56.9	58.9	63.0	70.8	53.7	58.4	60.3	67.8	52.8	58.7	59.6	66.1
101.01.10	57.2	62.4	66.8	76.1	56.6	57.2	65.3	72.0	53.3	57.6	58.6	71.6
101.02.10	56.4	63.1	61.4	82.4	50.3	56.8	63.7	72.4	54.5	55.7	63.7	73.1
101.03.23	47.4	54.1	49.9	77.7	57.3	60.1	59.8	80.4	51.7	51.9	55.7	68.5

註：採用行政院環保署 102 年 8 月 5 日公告修正：「噪音管制標準」之第六條「營建工程噪音管制標準」。

歷次營建噪音監測結果比較表(續 3)

單位：dB(A)

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>	
	75	100	75	100	75	100	75	100	75	100	75	100
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
101.04.09	56.4	63.6	65.4	79.1	64.7	70.7	69.6	81.4	53.6	57.3	61.4	69.2
101.05.14	52.7	60.9	69.6	86.2	54.0	60.8	62.2	69.9	55.0	60.2	65.8	80.0
101.06.11	50.2	58.4	60.4	73.1	57.6	63.5	71.5	77.4	56.8	62.4	65.6	72.9
101.07.09	54.6	65.1	60.3	85.2	50.1	56.7	57.9	67.5	58.4	61.4	65.8	78.0
101.08.15	64.4	66.3	70.4	86.6	62.1	68.4	70.8	78.9	62.2	66.8	66.3	83.6
101.09.10	58.1	60.7	67.5	75.7	56.4	62.3	61.7	77.9	59.1	65.0	69.6	81.8
101.10.22	49.0	56.3	59.0	68.5	52.1	57.8	59.9	77.3	51.7	59.7	62.3	76.1
101.11.21	48.0	54.8	54.4	71.9	49.5	60.9	58.6	75.2	54.4	60.8	64.9	74.5
101.12.10	51.8	54.4	59.6	79.0	48.9	52.3	54.4	59.9	52.0	59.9	58.7	77.6
102.01.25	57.3	63.1	65.9	81.2	56.3	62.9	65.3	76.9	59.3	64.1	69.1	77.4
102.02.19	53.0	58.6	54.7	82.1	56.2	64.4	59.9	69.9	59.8	67.6	68.5	76.9
102.03.15	56.0	62.2	59.5	77.5	53.4	54.7	55.1	77.8	54.0	59.6	55.1	77.7
102.04.17	49.5	55.1	50.8	75.0	45.0	46.5	47.2	63.7	54.0	54.4	55.0	69.1
102.05.13	50.2	55.4	51.2	79.0	50.0	52.7	57.8	69.5	43.6	57.9	45.9	78.4
102.06.05	55.1	60.5	68.8	83.4	57.3	60.0	63.8	84.8	53.3	60.5	55.9	81.7
102.07.26	56.7	56.7	71.9	71.9	64.4	67.0	69.8	91.4	65.6	67.7	67.9	79.6
102.08.23	56.5	63.1	57.6	76.6	58.4	62.5	64.1	77.1	56.7	63.7	58.2	76.3
102.09.02	54.0	57.5	55.7	76.7	42.3	57.2	44.7	73.8	57.5	62.8	64.6	83.0
102.10.25	57.2	65.6	58.7	86.3	55.9	64.2	61.4	84.9	57.2	64.0	65.0	84.1
102.11.22	59.8	63.6	61.6	84.3	51.4	54.6	53.5	62.0	52.1	59.2	54.5	75.6
102.12.02	51.9	61.3	57.5	79.0	57.2	62.3	60.7	80.5	61.3	64.8	68.3	86.3
103.01.27	56.1	58.1	57.4	84.3	46.9	55.4	49.3	74.7	47.5	55.9	51.0	73.6
103.02.11	52.2	59.5	56.3	78.3	51.6	56.1	56.3	75.8	53.3	56.2	56.1	80.0
103.03.02	49.5	56.1	56.6	75.8	53.6	58.2	59.9	75.0	45.6	53.0	48.7	62.3
103.04.21	56.4	60.9	58.3	77.4	57.2	64.2	60.6	81.5	51.4	56.9	52.7	74.4
103.05.12	57.1	63.1	61.4	81.2	61.9	64.3	64.1	83.9	60.5	64.3	69.1	82.8
103.06.05	52.4	56.9	52.7	76.0	58.1	62.3	60.1	72.5	52.0	55.6	57.4	74.3
103.07.25	62.7	67.8	63.6	86.4	55.4	58.3	56.7	80.2	57.8	61.4	58.9	74.9
103.08.06	58.3	66.7	59.7	89.9	62.4	66.2	65.4	84.3	59.6	66.5	61.7	75.3
103.09.02	54.8	58.1	57.4	76.4	53.4	55.8	55.1	69.6	56.7	57.8	60.6	72.2
103.10.22	54.6	58.1	55.4	78.8	54.4	55.1	56.1	75.1	56.6	57.0	57.7	78.0
103.11.24	53.7	59.9	54.9	80.4	50.5	53.3	53.1	75.8	57.9	64.7	59.4	82.0
103.12.05	48.3	53.7	49.4	71.7	53.5	59.0	55.9	79.7	48.0	55.1	49.9	71.9

註：採用行政院環保署 102 年 8 月 5 日公告修正：「噪音管制標準」之第六條「營建工程噪音管制標準」。

歷次營建噪音監測結果比較表(續 4)

單位：dB(A)

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>	
	75	100	75	100	75	100	75	100	75	100	75	100
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
104.01.26	54.3	61.1	58.6	82.8	58.6	63.6	61.6	79.8	48.0	51.3	49.9	67.9
104.02.04	51.0	57.6	52.7	76.0	53.0	60.1	55.0	78.7	55.7	64.5	58.8	80.1
104.03.03	54.5	59.6	55.5	78.5	50.0	61.2	57.0	79.4	50.0	53.8	51.2	74.7
104.04.24	54.0	56.4	55.8	79.9	52.4	58.9	53.7	76.8	55.1	59.8	56.9	77.6
104.05.06	49.4	63.1	55.5	82.0	53.2	64.3	60.4	82.8	50.2	61.6	51.8	79.1
104.06.04	46.1	55.4	47.0	79.9	53.4	59.6	54.9	71.4	53.0	53.7	56.4	70.7
104.07.27	59.0	67.8	59.7	92.8	57.3	65.0	61.7	87.1	57.0	60.9	66.3	80.8
104.08.03	54.2	60.5	56.1	78.2	51.9	59.4	54.3	80.5	49.5	58.4	51.5	79.3
104.09.01	58.9	63.4	60.2	86.3	52.3	55.2	56.3	68.6	50.1	57.0	52.7	72.7
104.10.28	56.1	59.3	57.1	76.1	45.6	54.2	48.2	74.0	47.0	53.9	50.0	67.3
104.11.09	54.4	58.3	55.2	80.9	52.3	55.9	53.5	75.0	55.4	59.2	56.0	74.8
104.12.02	51.8	55.9	53.6	70.8	52.2	57.9	53.8	74.1	51.5	59.9	55.4	73.7
105.01.29	51.4	56.8	52.8	72.5	52.8	56.1	54.6	76.2	55.3	60.8	57.3	75.4
105.02.02	52.9	59.8	55.1	74.2	54.5	61.9	55.9	81.1	51.9	59.0	55.4	79.7
105.03.02	56.3	64.4	59.9	85.1	55.1	58.6	57.8	78.5	54.9	62.6	57.1	79.5
105.04.25	54.2	61.3	56.1	84.1	54.1	64.3	55.9	78.8	54.2	62.5	56.4	77.1
105.05.05	59.8	64.5	63.1	86.0	53.6	59.8	56.9	76.2	62.1	66.0	64.5	79.7
105.06.01	58.0	63.4	60.2	78.9	55.4	62.0	57.4	85.2	54.6	57.5	56.5	76.5
105.07.21	49.2	61.8	50.4	76.2	47.0	55.9	53.1	72.7	51.8	62.4	53.7	72.7
105.08.01	57.8	60.1	62.0	78.3	54.8	67.2	59.2	77.8	59.9	67.0	63.3	85.4
105.09.01	54.9	58.5	59.9	76.9	45.5	58.6	47.9	76.2	44.1	69.1	46.6	78.6
105.10.26	54.4	64.8	56.4	80.9	55.5	60.0	57.8	80.9	41.4	54.2	44.5	74.1
105.11.03	63.0	69.5	68.5	87.2	54.3	70.2	56.1	81.6	59.0	65.8	63.8	81.4
105.12.01	41.3	61.9	43.3	77.4	51.3	55.2	54.4	74.2	43.8	54.7	46.3	69.4
106.01.23	53.7	61.9	56.4	78.8	57.1	63.6	57.8	80.4	52.4	57.8	56.8	75.4
106.02.03	46.4	51.4	49.7	65.1	51.3	62.2	52.9	84.3	47.0	55.1	49.1	69.6
106.03.01	50.7	57.1	51.6	71.3	49.9	59.1	51.2	79.9	51.1	65.9	53.4	79.4
106.04.26	47.4	55.7	49.7	69.9	42.5	53.9	44.6	67.9	41.3	45.4	43.9	64.0
106.05.05	46.5	61.1	50.4	81.5	46.6	52.8	52.5	69.2	45.8	52.6	49.1	74.0
106.06.01	49.8	60.5	50.4	75.6	50.7	57.6	52.2	80.1	51.1	55.8	56.5	66.9
106.07.26	46.7	60.5	49.4	87.0	46.8	60.4	49.9	74.9	45.0	52.5	47.8	69.3
106.08.01	53.5	62.0	56.2	74.7	52.5	53.4	53.8	74.0	52.4	59.3	54.4	72.1
106.09.04	49.1	55.9	55.9	73.5	52.9	63.0	56.8	75.2	47.8	56.1	50.9	75.9

註：採用行政院環保署 102 年 8 月 5 日公告修正：「噪音管制標準」之第六條「營建工程噪音管制標準」。

歷次營建噪音監測結果比較表(續 5)

單位：dB(A)

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>	
	75		100		75		100		75		100	
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
106.10.23	51.0	59.6	51.8	78.7	49.8	55.2	51.9	72.7	50.8	54.9	52.0	70.2
106.11.01	52.6	58.5	54.3	73.7	48.0	60.3	54.4	77.0	51.9	57.2	56.2	74.7
106.12.04	50.1	57.9	52.5	78.1	49.3	56.6	52.4	68.2	50.5	52.9	52.2	70.4
107.01.08	53.4	55.0	55.8	68.6	46.5	52.4	47.8	57.7	51.6	54.2	53.9	64.3
107.02.06	47.9	52.8	51.0	64.4	48.6	48.6	56.3	56.3	58.7	58.7	68.6	68.6
107.03.05	50.2	51.5	55.8	65.6	49.5	50.1	50.6	63.5	52.4	61.6	53.7	72.7
107.04.20	50.7	52.3	56.2	63.6	49.3	53.9	57.9	68.0	49.4	55.4	58.6	75.9
107.05.03	48.5	61.3	58.3	67.5	53.4	62.7	59.1	72.0	44.5	64.5	52.4	74.5
107.06.26	42.5	53.5	43.7	66.8	47.8	61.8	57.7	82.3	42.9	63.1	46.4	82.6
107.07.06	36.2	49.1	38.9	61.1	45.5	58.1	48.9	75.0	43.5	55.6	47.6	73.2
107.08.09	52.3	64.0	54.4	69.7	51.5	61.6	53.3	69.9	50.5	64.3	52.1	76.0
107.09.06	47.4	53.2	47.8	65.1	44.5	57.5	45.0	65.5	47.2	51.0	47.6	61.1
107.10.18	50.4	59.0	51.6	73.2	62.4	64.5	63.1	70.4	57.7	65.3	60.1	72.7
107.11.08	59.4	61.7	62.1	75.8	52.5	54.8	53.6	65.5	48.0	48.7	50.7	62.7
107.12.04	40.9	55.4	44.1	68.3	50.8	65.7	54.0	78.1	58.5	67.6	64.8	79.2
108.01.28	59.5	60.6	61.1	75.8	50.9	55.1	60.9	71.9	52.6	56.7	60.9	71.9
108.02.12	58.4	63.0	65.2	79.4	54.0	62.1	54.9	81.8	54.4	58.7	55.0	77.5
108.03.05	49.0	57.8	53.5	70.5	47.7	53.6	50.9	75.8	47.5	50.8	50.2	74.7
108.04.22	62.3	69.2	69.6	87.8	51.4	58.9	52.7	77.1	58.3	60.9	63.7	80.1
108.05.03	54.4	68.8	56.5	85.7	55.8	62.1	57.3	84.7	54.7	62.9	56.2	78.0
108.06.04	55.5	60.0	57.2	75.6	55.5	65.8	57.6	84.3	54.4	58.7	60.4	81.8
108.07.22	66.4	70.2	72.8	89.6	56.0	60.7	59.8	73.2	51.6	56.6	53.3	71.9
108.08.02	50.7	70.4	55.1	85.3	53.7	60.7	54.7	77.2	49.3	56.7	51.1	75.5
108.09.03	57.2	71.0	59.7	86.3	53.1	57.4	54.1	69.7	52.0	57.4	54.4	79.3
108.10.21	49.9	57.9	51.6	75.8	56.6	62.3	57.5	79.7	66.4	70.5	70.9	83.2
108.11.14	49.5	56.6	50.8	73.8	45.2	58.3	46.7	73.7	51.1	71.0	52.2	87.1
108.12.03	54.7	66.5	56.1	83.0	48.6	61.9	50.7	79.2	50.4	68.8	51.7	83.1
109.01.02	56.9	64.3	64.3	71.1	65.6	67.1	69.9	84.6	61.2	63.8	67.5	78.3
109.02.03	52.2	62.9	53.2	74.7	51.0	70.7	53.0	87.7	52.5	54.6	54.7	71.1
109.03.05	56.5	59.3	57.7	76.7	62.0	65.8	63.9	80.8	56.3	70.0	59.4	86.8
109.04.24	57.8	63.6	58.9	84.6	49.3	60.8	53.2	80.0	50.9	56.3	54.8	75.5
109.05.18	54.5	57.8	59.0	76.2	53.2	59.5	56.5	77.6	54.0	58.2	55.9	74.0
109.06.15	50.5	51.4	50.9	65.0	47.6	52.9	48.0	72.8	59.5	61.2	63.5	80.5

註：採用行政院環保署 102 年 8 月 5 日公告修正：「噪音管制標準」之第六條「營建工程噪音管制標準」。

歷次營建噪音監測結果比較表(續 6)

單位：dB(A)

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>		L <sub>eq</sub>		L <sub>max</sub>	
	75		100		75		100		75		100	
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
109.07.01	57.6	66.6	60.0	87.1	47.6	56.5	50.0	71.1	42.2	55.1	46.0	69.4
109.08.17	51.6	52.5	51.9	71.1	47.9	57.3	48.6	75.1	53.2	54.1	54.0	71.9
109.09.14	47.0	50.5	48.9	60.6	46.9	66.9	48.3	80.7	48.0	55.4	48.6	69.1
109.10.06	50.8	59.3	52.1	78.0	52.3	55.8	55.7	71.0	48.5	61.7	49.1	73.1
109.11.16	49.5	54.6	53.1	77.0	51.4	65.5	54.8	86.2	55.7	62.4	58.3	84.5
109.12.14	46.3	49.8	48.4	70.5	45.9	56.3	48.1	67.9	47.3	59.6	49.3	77.3
110.01.06	42.7	49.0	49.0	70.4	46.8	60.5	49.0	81.2	58.1	59.0	66.8	80.3
110.02.01	50.3	51.8	57.3	76.4	47.0	47.7	47.4	69.0	48.0	61.9	49.5	79.5
110.03.04	49.2	54.9	56.4	70.7	47.2	51.3	47.7	71.9	50.2	63.7	53.0	85.1
110.04.06	53.8	58.8	57.7	75.7	50.5	58.2	52.5	84.6	40.8	56.4	41.5	74.4
110.05.03	59.5	62.8	63.0	72.9	58.2	63.7	62.4	73.0	61.2	63.0	67.5	77.0
110.06.04	53.8	59.7	59.9	78.7	55.6	60.5	57.9	84.6	55.6	60.6	57.5	80.0
110.07.07	44.0	50.4	46.2	69.1	43.5	56.7	45.7	70.9	49.4	60.9	51.2	81.1
110.08.10	64.2	67.4	66.7	85.7	59.2	63.4	59.6	83.4	61.5	64.8	62.8	79.7
110.09.03	45.8	56.9	47.3	65.8	42.2	49.0	43.4	63.2	51.0	59.2	55.1	71.5
110.10.08	52.8	55.2	53.7	72.8	49.4	58.6	50.9	78.4	49.5	58.5	51.5	73.6
110.11.19	46.6	48.9	47.6	72.7	49.3	54.8	55.1	77.3	56.2	58.8	57.9	76.1
110.12.03	63.4	63.4	61.3	83.0	65.7	65.7	64.2	85.1	60.0	60.0	56.5	80.0
111.01.07	51.1	53.9	52.5	76.4	57.5	64.5	61.6	83.2	56.3	64.1	58.2	84.5
111.02.18	49.2	49.8	53.3	67.4	60.3	61.4	64.1	84.5	59.7	61.5	62.2	80.1
111.03.04	52.6	55.9	54.5	83.3	55.1	62.8	59.5	78.3	49.4	54.3	50.4	72.1

註：採用行政院環保署 102 年 8 月 5 日公告修正：「噪音管制標準」之第六條「營建工程噪音管制標準」。

歷次營建振動監測結果比較表

單位：dB

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>	
	75		-		75		-		75		-	
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
93.10.25	30.0	34.2	57.4	60.0	30.0	31.2	58.1	61.3	30.0	36.4	-	67.9
93.11.22	36.4	44.7	48.7	51.2	30.0	35.8	41.7	50.8	31.6	41.8	45.3	51.0
93.12.06	30.0	37.9	47.6	58.7	30.0	42.3	56.3	61.6	30.2	45.0	46.7	57.1
94.01.04	36.4	38.4	42.3	59.1	36.8	47.6	41.6	54.6	40.3	47.6	51.4	54.6
94.01.11	35.8	39.1	42.6	47.8	32.6	36.3	48.3	49.1	31.2	36.4	36.3	41.2
94.02.14	34.6	37.8	41.4	49.3	31.4	33.4	44.3	46.5	31.3	35.9	38.4	43.8
94.03.08	43.2	44.2	49.0	55.4	39.4	41.6	45.1	50.0	48.6	60.8	54.9	68.2
94.04.14	34.2	45.3	46.1	52.8	32.1	34.6	41.3	48.8	40.2	52.1	45.6	58.0
94.04.26	33.6	41.2	41.5	47.7	30.6	34.6	38.4	42.3	33.8	42.2	38.7	49.3
94.05.09	-	-	-	-	30.7	33.4	36.8	40.8	31.9	32.7	35.2	39.8
94.05.23	-	-	-	-	31.4	43.8	35.9	47.1	40.8	48.7	46.3	56.8
94.06.01	36.1	38.2	43.2	47.9	39.1	40.4	40.4	49.4	41.6	43.6	44.1	47.8
94.06.17	32.9	39.6	45.6	43.1	33.2	38.2	45.8	42.6	33.8	41.9	46.7	47.2
94.07.05	31.1	43.8	36.6	49.4	35.4	54.6	41.5	59.0	30.2	31.5	30.8	35.4
94.07.22	33.3	38.5	41.8	44.6	35.9	38.0	40.5	41.3	34.2	35.9	37.5	38.3
94.08.01	40.1	44.3	47.2	48.5	31.3	36.4	36.5	45.1	30.0	32.4	30.8	39.5
94.08.11	35.1	41.0	40.3	45.2	32.8	33.3	38.5	35.6	44.5	50.7	51.7	55.9
94.09.05	30.0	33.4	30.0	42.0	30.0	36.2	30.0	53.4	30.0	37.0	30.0	57.7
94.09.13	33.2	35.7	37.1	38.8	33.7	35.9	35.0	37.3	34.1	47.2	41.1	52.0
94.10.03	-	45.2	-	48.4	35.8	54.2	39.8	63.1	31.0	36.6	34.5	41.7
94.10.18	41.5	45.1	41.9	51.8	35.7	43.4	37.1	48.7	35.6	49.3	37.5	50.8
94.11.01	30.0	33.4	30.0	35.8	30.0	36.8	30.0	40.1	30.0	31.9	30.0	39.8
94.11.17	31.7	45.7	33.2	51.2	30.0	37.6	32.6	42.1	41.0	43.4	41.5	48.7
94.12.01	30.0	52.0	37.5	55.6	30.0	34.2	30.0	43.7	30.0	30.0	30.0	35.7
94.12.15	30.7	31.6	34.8	37.1	30.0	50.9	30.0	60.8	30.0	31.4	30.0	38.1
95.01.20	36.3	39.6	41.2	48.3	31.9	34.2	41.1	42.3	33.2	35.3	38.1	39.5
95.02.22	34.8	35.3	42.9	44.5	33.2	34.0	42.4	43.8	33.0	34.0	41.4	44.6
95.03.23	36.6	37.7	46.6	52.6	41.9	42.0	54.6	56.7	41.3	42.3	52.6	56.5
95.04.19	30.2	32.1	35.6	40.9	40.7	42.0	50.5	51.4	31.9	45.5	39.8	58.1
95.05.26	33.3	40.2	50.9	63.5	33.2	40.1	41.3	66.1	34.1	57.3	46.9	67.4
95.06.22	38.1	42.5	53.4	61.0	36.1	43.1	57.2	63.4	41.0	47.6	58.7	65.3
95.07.20	37.9	40.0	54.1	54.9	33.3	36.4	40.9	48.3	38.6	43.3	50.8	61.0
95.08.18	30.2	31.0	41.9	48.8	30.6	33.4	47.3	46.5	33.2	39.4	44.2	51.4

註:1.我國目前尚無振動管制標準，故參考「日本振動規制法施行細則」第二種區域基準值進行評估。  
2.”-“表無此測值。



歷次營建振動監測結果比較表(續 1)

單位：dB

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>	
	75		-		75		-		75		-	
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
95.09.20	39.9	40.4	46.6	55.1	35.9	50.0	50.7	52.8	34.9	49.4	42.2	58.6
95.10.26	30.4	31.5	38.3	42.5	31.3	32.9	38.0	41.5	31.6	33.1	38.2	45.5
95.11.24	36.9	38.2	48.2	47.7	35.5	37.2	44.7	45.2	31.6	32.1	41.7	40.0
95.12.18	36.5	41.4	41.5	47.8	36.5	40.5	43.9	48.0	34.8	33.6	42.6	43.2
96.01.22	45.3	51.0	59.7	61.5	42.9	45.6	58.0	58.3	45.6	46.3	59.0	60.1
96.02.01	30.4	42.5	38.3	48.9	39.9	40.2	52.1	53.4	34.9	41.5	48.4	60.2
96.03.01	30.0	30.8	34.0	43.0	33.9	35.9	45.4	48.2	35.6	35.9	47.4	47.4
96.04.16	45.3	51.0	59.7	61.5	42.9	45.6	58.0	58.3	45.6	46.3	59.0	60.1
96.05.08	30.4	42.5	38.3	48.9	39.9	40.2	52.1	53.4	34.9	41.5	48.4	60.2
96.06.06	30.0	30.8	30.4	43.0	33.9	35.9	45.4	47.4	35.6	35.9	47.4	47.4
96.07.16	30.6	31.1	46.2	48.2	38.4	39.6	51.3	54.3	34.0	36.2	43.4	48.6
96.08.01	30.3	30.6	37.9	48.1	31.3	32.9	45.2	53.4	30.5	31.6	42.1	44.8
96.09.21	30.2	30.3	40.0	40.7	30.0	33.4	34.1	56.5	30.0	31.0	31.6	45.0
96.10.22	40.5	41.5	48.1	51.2	38.5	40.2	44.8	47.5	39.0	42.1	48.2	49.6
96.11.06	33.1	32.9	41.1	43.7	32.2	31.5	43.1	41.3	30.5	32.9	37.2	43.2
96.12.10	31.2	32.5	40.9	42.4	32.2	32.4	45.3	40.9	31.8	33.1	42.5	48.5
97.01.29	31.0	45.3	41.2	69.0	39.0	51.9	46.9	77.4	32.3	36.2	41.1	57.7
97.02.15	33.5	34.5	41.8	46.0	31.8	32.7	42.6	46.8	32.0	32.9	43.2	45.2
97.03.11	35.0	32.5	41.4	47.3	35.8	34.5	45.8	46.2	31.9	36.1	41.4	47.8
97.04.08	31.0	39.9	37.0	46.3	36.9	40.1	55.8	42.5	30.1	35.9	36.9	48.2
97.05.05	31.9	37.8	39.2	52.7	30.5	32.5	39.7	41.4	31.0	33.3	41.3	44.0
97.06.10	40.8	42.8	49.3	51.2	39.8	40.8	47.9	48.2	43.8	44.2	49.2	51.3
97.07.15	30.5	30.4	39.9	37.4	36.4	41.5	44.3	45.6	31.6	33.6	44.6	47.2
97.08.05	35.7	40.5	44.4	46.8	42.0	42.5	45.8	48.4	31.6	39.6	44.6	58.0
97.09.01	30.1	31.9	34.1	46.3	30.0	30.1	32.3	35.7	30.1	32.4	36.7	42.1
97.10.09	34.3	46.3	42.5	56.8	33.7	33.8	37.0	39.5	32.8	33.9	38.4	41.6
97.11.04	31.9	34.9	34.7	39.5	36.7	42.0	42.2	45.8	30.1	34.1	36.9	40.2
97.12.02	33.8	34.7	38.9	39.2	35.4	42.8	43.5	45.6	31.9	33.2	34.8	39.8
98.01.08	33.3	33.7	38.6	39.2	32.9	34.0	41.8	41.2	32.4	34.5	38.5	42.5
98.03.03	32.8	33.1	45.3	45.2	33.3	35.3	45.9	46.8	32.4	33.5	45.3	46.8
98.04.07	33.5	33.7	40.8	41.8	32.3	33.0	40.0	40.1	31.0	31.7	37.5	39.3
98.05.14	31.5	35.0	42.8	45.7	30.2	32.5	40.3	42.9	30.7	32.0	39.8	42.0
98.06.11	36.7	40.2	44.1	45.5	34.4	37.8	41.6	42.2	32.8	33.1	34.2	36.7
98.07.02	30.0	32.3	32.5	35.3	30.0	32.1	31.3	33.8	30.0	32.2	30.0	36.1

註:我國目前尚無振動管制標準，故參考「日本振動規制法施行細則」第二種區域基準值進行評估。

歷次營建振動監測結果比較表(續 2)

單位：dB

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>	
	75		-		75		-		75		-	
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
98.08.06	37.2	45.9	41.2	57.5	45.7	46.2	59.7	59.1	43.5	46.3	54.6	59.3
98.09.04	30.0	30.0	30.0	34.5	30.0	30.1	33.5	33.9	30.0	30.0	30.0	34.3
98.10.13	50.4	50.1	57.3	59.0	49.4	50.0	58.5	58.2	48.2	51.1	57.9	61.3
98.11.10	42.6	43.1	50.1	49.7	42.3	42.1	49.3	50.1	42.1	44.7	51.3	54.0
98.12.10	30.0	45.0	32.9	46.4	30.0	44.9	31.3	46.8	30.1	46.7	33.4	68.5
99.01.04	43.5	43.6	57.9	62.9	45.3	49.0	65.4	69.8	44.1	45.8	56.0	66.9
99.02.09	48.6	48.2	50.1	49.0	48.1	48.3	50.7	49.1	38.8	39.1	42.7	49.7
99.03.08	36.8	37.8	46.0	47.3	38.3	39.4	47.2	47.4	39.1	37.4	45.8	48.3
99.04.07	30.5	34.7	38.9	38.5	30.0	33.6	33.6	37.6	30.7	33.4	36.0	37.1
99.05.11	34.7	35.2	40.3	43.1	34.8	35.5	41.0	43.4	35.0	35.2	38.2	39.8
99.06.07	30.9	35.6	39.9	46.1	31.4	38.0	39.4	47.8	31.7	37.3	38.6	47.9
99.07.12	30.1	32.2	31.8	38.5	30.3	32.2	38.9	37.7	30.3	32.0	36.0	37.1
99.08.19	47.6	47.8	56.7	57.5	47.7	49.2	58.1	57.2	43.2	44.7	53.1	56.1
99.09.03	44.3	44.9	56.1	56.3	44.1	46.0	57.0	57.2	44.0	45.2	54.9	53.4
99.10.05	44.5	47.1	56.1	58.7	43.7	48.1	54.2	58.9	43.6	46.7	51.7	60.3
99.11.03	30.1	34.5	38.1	47.3	30.0	30.6	31.7	34.3	30.0	30.6	36.1	38.2
99.12.09	37.7	38.1	41.7	42.6	37.7	38.6	41.3	42.9	37.6	39.1	41.2	43.4
100.01.06	31.2	43.2	39.7	58.5	32.2	43.1	44.3	57.2	31.3	42.8	38.5	46.8
100.02.24	30.0	30.4	37.9	40.7	30.4	30.9	40.9	43.2	30.2	30.6	37.1	38.4
100.03.15	35.1	36.3	39.5	44.5	35.3	36.4	44.8	44.7	35.2	36.4	43.8	38.5
100.04.14	31.3	42.5	47.2	52.2	34.7	41.0	54.4	50.0	30.0	40.5	33.0	44.0
100.05.09	31.5	33.2	48.0	52.2	31.1	37.3	44.3	52.6	37.7	38.1	54.2	41.0
100.06.09	30.9	37.3	30.9	37.3	39.1	54.7	45.0	58.9	42.1	44.7	51.3	54.0
100.07.27	39.7	41.9	42.6	51.8	36.1	39.9	49.3	43.0	39.6	53.4	44.5	69.8
100.08.19	36.0	36.2	39.7	43.1	35.1	37.5	44.1	48.8	36.9	43.7	45.9	56.4
100.09.02	30.1	35.8	31.9	52.9	30.1	34.7	36.4	40.2	30.7	35.9	43.9	51.2
100.10.06	30.0	30.3	31.2	41.8	30.0	30.0	34.6	34.6	30.0	30.7	31.5	38.4
100.11.17	30.0	30.1	30.7	34.9	30.1	38.5	35.2	42.4	30.0	30.1	33.1	34.5
100.12.12	30.0	30.0	30.0	31.4	30.0	30.0	30.5	33.1	30.0	30.0	30.0	33.1
101.01.10	30.0	30.1	35.2	36.1	30.0	30.1	34.6	35.7	30.0	30.1	35.3	34.4
101.02.10	30.2	37.0	36.8	42.0	30.0	33.2	32.3	52.7	30.3	41.4	36.4	45.6
101.03.23	34.3	39.9	36.8	47.5	33.5	38.6	34.7	62.1	33.7	39.3	34.7	64.6
101.04.09	30.0	35.5	34.4	39.6	30.0	36.8	37.8	47.1	30.0	37.9	34.4	39.9
101.05.14	36.0	37.9	39.4	63.7	47.6	50.7	52.9	58.7	35.1	37.8	38.8	59.1

註:我國目前尚無振動管制標準，故參考「日本振動規制法施行細則」第二種區域基準值進行評估。

歷次營建振動監測結果比較表(續 3)

單位：dB

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>	
	75		-		75		-		75		-	
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
101.06.11	32.0	38.1	36.4	58.6	30.6	36.8	33.0	46.7	30.0	38.2	34.4	40.2
101.07.09	35.1	34.8	37.4	50.5	36.6	41.8	38.4	53.6	35.7	35.9	37.7	52.0
101.08.15	30.1	36.2	32.0	33.9	34.4	33.7	37.4	43.2	32.4	37.1	42.0	49.7
101.09.10	33.4	37.9	34.7	42.5	30.0	38.3	33.2	39.9	30.0	37.9	31.4	41.9
101.10.22	30.0	37.9	31.2	48.4	32.5	35.7	39.7	54.1	31.3	33.8	33.6	46.8
101.11.21	35.5	36.4	41.3	53.4	36.3	36.1	39.8	70.1	40.4	41.8	45.2	54.9
101.12.10	30.0	37.5	30.3	39.7	33.1	40.3	33.9	45.8	30.0	32.7	35.0	36.9
102.01.25	33.0	35.1	33.6	39.9	33.1	40.2	33.9	50.7	32.7	36.2	33.8	53.8
102.02.19	31.6	38.0	39.8	39.9	30.0	37.6	33.2	39.9	30.0	37.6	31.3	39.9
102.03.15	31.9	31.4	31.9	48.3	38.1	39.9	43.1	63.2	35.1	39.9	36.5	65.8
102.04.17	33.1	48.8	33.1	61.3	34.2	34.2	34.2	49.7	33.1	38.9	33.1	66.2
102.05.13	31.2	34.3	31.2	46.3	35.4	35.3	35.4	47.0	39.6	42.9	39.6	53.2
102.06.05	27.8	30.0	28.9	56.3	27.7	29.7	28.6	44.0	22.5	38.6	23.7	58.2
102.07.26	32.9	37.9	38.9	43.3	37.1	40.6	39.9	62.8	30.0	42.4	30.8	71.4
102.08.23	36.8	36.8	47.1	47.1	37.9	40.6	42.2	65.3	33.3	34.9	33.3	54.9
102.09.02	35.7	45.2	35.7	58.8	34.5	36.5	36.6	49.4	35.9	36.3	35.9	51.8
102.10.25	33.6	37.4	33.6	55.4	32.1	33.7	32.1	55.4	33.8	36.2	33.8	44.3
102.11.22	33.1	35.9	33.1	59.5	43.3	52.4	43.3	59.7	32.3	34.3	32.3	41.6
102.12.02	31.0	35.3	33.5	47.8	33.4	37.6	33.4	49.6	35.9	39.5	35.9	58.6
103.01.27	33.0	34.6	33.0	45.8	32.4	38.7	32.4	50.5	33.2	37.0	33.2	54.6
103.02.11	36.7	44.0	36.7	51.6	31.9	35.0	31.9	43.5	34.8	37.7	34.9	43.5
103.03.02	40.6	48.4	40.6	56.4	33.3	33.7	33.3	49.3	31.3	33.4	31.3	46.8
103.04.21	30.0	37.7	30.0	46.0	30.0	38.1	30.0	49.9	32.0	40.9	32.0	46.6
103.05.12	35.0	40.5	35.0	46.8	32.1	33.4	32.1	40.1	31.5	32.8	31.5	51.4
103.06.05	32.6	37.9	32.6	39.9	30.0	38.0	33.2	39.9	30.0	34.5	30.0	41.1
103.07.25	35.6	36.2	35.6	44.8	34.2	36.8	34.2	49.0	33.3	36.4	33.3	48.7
103.08.06	35.7	39.5	35.7	47.2	32.7	38.2	32.7	41.5	33.5	38.0	33.5	41.0
103.09.02	39.4	48.0	39.4	53.7	34.9	37.0	34.9	48.1	39.8	48.2	39.8	57.9
103.10.22	33.8	37.4	33.8	47.5	33.6	36.9	33.6	59.8	33.9	38.6	33.9	45.0
103.11.24	35.7	40.3	35.9	49.5	34.5	40.5	36.6	49.7	35.9	38.3	35.9	49.8
103.12.05	31.9	36.8	34.4	49.0	31.8	34.6	31.8	41.2	34.8	38.4	34.8	46.4
104.01.26	36.9	39.0	36.9	47.5	35.3	39.4	35.3	47.8	31.9	35.5	31.9	44.2
104.02.04	36.2	40.7	36.2	52.6	35.7	53.1	35.7	56.4	32.5	35.3	32.5	45.7
104.03.03	31.5	33.1	31.5	40.5	32.6	35.8	32.6	44.9	33.9	36.7	33.9	48.0

註:我國目前尚無振動管制標準，故參考「日本振動規制法施行細則」第二種區域基準值進行評估。

歷次營建振動監測結果比較表(續 4)

單位：dB

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>	
	75		-		75		-		75		-	
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
104.04.24	39.3	47.9	39.3	64.9	32.5	39.0	32.5	51.9	32.2	33.7	32.2	44.9
104.05.06	30.9	31.5	30.9	54.1	30.9	35.9	30.9	51.3	32.2	38.1	32.2	56.1
104.06.04	32.7	39.6	32.7	51.7	34.7	38.9	34.7	54.8	32.2	42.9	32.2	54.5
104.07.27	31.4	34.5	31.4	56.6	31.9	35.7	31.9	47.2	31.6	36.3	31.6	43.2
104.08.03	31.3	37.8	31.3	39.9	32.4	36.2	32.4	53.5	33.1	38.5	33.1	48.7
104.09.01	32.3	37.2	32.3	47.5	31.1	36.0	31.1	51.5	39.8	43.9	39.8	50.7
104.10.28	32.2	37.1	32.2	47.3	30.4	39.5	30.4	49.6	39.1	40.9	39.1	50.1
104.11.09	32.1	33.2	32.1	52.0	32.6	35.7	32.6	53.2	33.5	38.8	33.5	55.6
104.12.02	39.7	48.3	39.7	56.2	38.6	40.6	38.6	54.5	37.7	40.1	37.7	48.5
105.01.29	32.3	35.6	32.3	44.7	34.8	49.6	34.8	56.1	34.8	40.6	34.8	46.7
105.02.02	33.6	34.9	33.6	44.8	34.7	37.0	34.7	46.3	33.1	35.5	33.1	46.6
105.03.02	33.6	35.7	33.6	44.3	32.9	36.0	32.9	48.6	34.2	40.0	34.2	54.3
105.04.25	31.8	34.2	31.8	52.6	30.9	31.6	30.9	48.1	41.9	47.4	41.9	60.9
105.05.05	34.1	40.3	34.1	54.8	31.2	35.1	31.2	43.7	33.9	36.2	33.9	44.8
105.06.01	32.5	35.1	32.5	55.2	31.7	32.8	31.7	53.1	36.9	43.2	36.9	52.2
105.07.21	31.3	34.1	31.3	41.0	32.5	37.9	32.5	45.5	32.1	35.2	32.1	38.1
105.08.01	32.4	37.0	32.4	59.7	31.4	39.1	31.1	49.0	31.9	33.5	31.9	67.7
105.09.01	32.8	37.0	32.8	43.7	32.9	33.6	32.9	48.8	32.6	38.3	32.6	44.2
105.10.26	43.0	46.3	43.0	67.5	33.3	48.0	33.3	59.7	39.2	44.1	39.2	51.1
105.11.03	46.6	61.0	46.6	70.4	34.3	42.8	34.3	68.4	34.3	44.7	34.3	63.4
105.12.01	34.3	38.2	34.3	42.0	32.2	39.6	32.2	48.6	33.4	38.3	33.4	48.7
106.01.23	44.5	48.0	44.5	86.1	38.4	53.4	38.4	62.4	49.4	57.2	49.4	68.8
106.02.03	32.9	37.8	32.9	54.1	32.0	36.6	32.0	43.6	32.8	36.0	32.8	45.5
106.03.01	31.7	32.4	31.7	44.7	31.6	35.5	31.6	65.4	31.2	32.8	31.2	67.9
106.04.26	43.8	46.7	43.8	50.5	31.4	32.8	31.4	51.7	34.7	37.4	34.7	43.6
106.05.05	37.9	43.7	37.9	55.7	37.2	38.1	37.2	65.1	32.5	39.4	32.5	59.7
106.06.01	31.6	37.6	31.6	47.1	32.7	39.1	32.7	46.4	32.8	33.4	32.8	46.8
106.07.26	32.8	42.0	32.8	49.4	32.3	34.3	32.3	44.0	31.6	33.9	31.6	44.6
106.08.01	39.9	44.1	39.9	64.6	35.0	43.3	35.0	49.8	34.1	38.3	34.1	48.8
106.09.04	33.7	35.7	33.7	39.9	31.5	32.6	31.5	36.0	30.9	31.5	30.9	36.9
106.10.23	32.8	36.1	32.8	47.2	32.8	41.1	32.8	51.5	30.9	36.8	30.9	49.0
106.11.01	31.9	42.3	31.9	45.1	30.9	37.4	30.9	43.0	33.8	36.1	33.8	39.9
106.12.04	33.0	37.7	33.0	45.3	31.6	34.2	31.6	53.3	32.7	35.0	32.7	43.5
107.01.08	32.8	36.0	32.8	45.5	32.0	36.6	32.0	43.6	32.9	37.8	32.9	54.1

註:我國目前尚無振動管制標準，故參考「日本振動規制法施行細則」第二種區域基準值進行評估。

歷次營建振動監測結果比較表(續 5)

單位：dB

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>	
	75		-		75		-		75		-	
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
107.02.06	—	55.7	—	63.1	—	45.5	—	54.4	—	55.1	—	64.4
107.03.05	—	30.4	—	35.1	—	30.0	—	30.0	—	30.0	—	31.1
107.04.20	30.0	31.9	30.0	34.5	30.0	30.5	30.0	35.7	30.0	31.4	30.0	34.5
107.05.03	30.9	38.3	35.1	53.4	31.5	31.9	37.0	38.6	30.0	30.1	30.0	34.0
107.06.26	30.1	30.5	36.2	40.9	30.0	30.0	31.7	34.6	31.5	31.5	33.7	43.7
107.07.06	30.1	31.3	31.2	39.9	30.0	30.3	30.0	34.0	30.0	32.3	30.0	45.0
107.08.09	30.0	30.1	30.0	33.1	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
107.09.06	30.1	36.0	30.5	40.5	30.9	34.0	32.5	39.8	30.6	35.5	32.6	50.9
107.10.18	30.0	31.7	30.0	42.6	30.0	35.2	30.0	49.2	30.0	30.0	30.0	30.9
107.11.08	30.4	32.4	30.9	41.2	30.1	32.6	30.2	39.9	30.0	30.4	30.0	39.3
107.12.04	30.0	30.4	31.6	35.2	30.0	30.1	31.0	32.2	34.7	36.9	48.9	58.0
108.01.28	30.1	30.6	30.4	39.4	30.0	30.1	30.4	39.9	30.0	32.9	30.0	43.9
108.02.12	37.3	46.7	37.3	52.6	30.1	30.8	30.1	41.7	35.5	36.4	35.5	46.7
108.03.05	39.9	54.7	39.9	63.7	31.0	35.9	31.0	61.5	33.8	53.5	33.8	62.6
108.04.22	45.8	52.2	45.8	64.4	38.3	49.4	38.3	62.9	30.0	32.6	30.0	60.0
108.05.03	30.3	35.7	30.3	43.3	30.3	40.8	30.3	48.0	30.1	41.7	30.1	53.6
108.06.04	31.9	37.8	31.9	58.7	39.1	46.6	39.1	60.1	36.9	40.5	36.9	58.9
108.07.22	36.1	36.8	36.1	51.3	30.0	35.5	30.0	57.3	30.0	34.7	30.0	47.2
108.08.02	42.9	51.7	42.9	62.7	37.6	47.8	37.6	49.9	30.0	34.1	30.0	45.0
108.09.03	30.0	36.3	30.0	49.2	30.0	52.0	30.0	62.4	30.0	30.4	30.0	53.0
108.10.21	32.7	37.3	32.7	51.1	30.0	36.9	30.0	42.0	30.0	34.6	30.0	56.5
108.11.14	30.0	30.7	30.0	55.7	34.2	56.3	34.2	66.4	33.3	55.2	33.3	65.2
108.12.03	32.1	35.2	32.1	47.6	30.9	35.2	30.9	46.2	31.3	40.4	31.3	53.9
109.01.02	30.8	32.9	30.8	38.0	30.8	32.8	30.8	34.9	31.7	36.7	31.7	43.7
109.02.03	34.5	33.2	34.5	47.8	46.6	48.6	46.6	54.4	41.9	39.4	41.9	56.2
109.03.05	32.2	34.4	32.2	47.5	39.6	38.2	39.6	56.0	30.0	32.6	30.0	40.5
109.04.24	30.5	39.4	30.5	56.0	32.3	43.9	32.3	68.9	36.8	48.1	36.8	68.2
109.05.18	33.6	37.7	33.6	39.9	32.0	34.4	32.0	39.4	32.4	37.9	32.4	39.9
109.06.15	34.5	36.9	34.5	57.1	30.0	35.1	30.0	54.9	36.2	41.6	36.2	73.3
109.07.01	30.0	36.7	30.0	45.8	30.0	32.1	30.0	53.1	30.0	34.5	30.0	47.9
109.08.17	33.9	39.7	33.9	62.8	30.0	40.4	30.0	60.1	30.0	35.4	30.0	51.2
109.09.14	30.0	33.2	30.0	35.9	30.0	30.6	30.0	41.6	30.0	31.1	30.0	42.2
109.10.06	30.0	34.7	30.0	69.5	30.0	49.1	30.0	49.9	31.6	38.1	31.6	44.4

註:我國目前尚無振動管制標準，故參考「日本振動規制法施行細則」第二種區域基準值進行評估。

歷次營建振動監測結果比較表(續 6)

單位：dB

測站	測點一				測點二				測點三			
管制區類別	第三類				第三類				第三類			
管制標準	L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>		L <sub>v10</sub>		L <sub>vmax</sub>	
	75		-		75		-		75		-	
日期	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測	背景	實測
109.11.16	30.0	48.0	30.0	52.1	30.0	37.6	30.0	56.2	30.0	35.3	30.0	55.3
109.12.14	32.4	43.9	32.4	51.7	43.2	45.3	43.2	61.9	37.8	44.8	37.8	54.4
110.01.06	30.2	30.3	30.2	80.0	34.2	50.3	34.2	57.3	36.9	49.2	36.9	58.6
110.02.01	30.3	35.2	30.3	56.7	30.0	36.2	30.0	59.5	30.0	33.1	30.0	61.9
110.03.04	30.0	32.4	30.0	54.4	30.0	34.6	30.0	58.0	30.0	30.4	30.0	41.5
110.04.06	30.0	38.2	30.0	39.9	30.0	34.2	30.0	80.5	30.0	32.9	30.0	48.0
110.05.03	38.6	41.8	38.6	49.7	30.0	32.9	30.0	54.6	30.5	39.4	31.5	50.8
110.06.04	47.1	51.3	47.1	65.6	31.8	34.9	31.8	49.9	43.2	48.3	43.2	49.9
110.07.07	32.8	33.9	32.8	44.6	31.1	32.0	31.1	50.4	31.8	36.0	31.8	43.5
110.08.10	30.0	32.1	30.0	42.2	30.0	32.8	30.0	46.6	30.0	34.5	30.0	44.0
110.09.03	30.0	36.5	30.0	39.9	30.0	37.7	30.0	44.7	30.1	35.6	30.1	39.7
110.10.08	37.5	39.9	37.5	44.9	30.0	38.6	30.0	40.4	30.0	41.8	30.0	47.2
110.11.19	30.6	34.4	30.6	42.8	31.7	38.0	31.7	44.8	32.5	35.6	32.5	44.4
110.12.03	30.0	38.6	30.0	48.2	30.0	35.4	30.0	50.9	30.0	37.3	30.0	39.9
111.01.07	34.6	38.1	34.6	45.7	35.3	48.4	35.3	56.6	34.8	43.4	34.8	58.8
111.02.18	30.0	38.0	30.0	46.0	30.0	35.7	30.0	44.4	34.7	37.8	34.7	45.1
111.03.04	33.5	42.8	33.5	59.7	40.0	43.2	40.0	50.7	37.2	40.1	37.2	51.9

註:我國目前尚無振動管制標準，故參考「日本振動規制法施行細則」第二種區域基準值進行評估。